




List of models

Program controller for operating RCA2/RCA Series actuators. One unit can handle various controls.

| Туре | С | | |
|------------------------|--|--|--|
| Name | Program mode | Positioner Mode | |
| External view | | | |
| Description | Both the actuator operation and communication with external equipment can be handled by a single controller. When two axes are connected, arc interpolation, path operations, and synchronization can be performed. | Up to 1500 positioning points are supported. Push-motion operation and teaching operation are also possible. | |
| Position points | 1500 | points | |
| Number of control axes | Up to | 2 axes | |

Model



567 ASEL





Controllers

PMEC /AMEC

PSEP /ASEP

ROBO NET |

ERC2

PCON

ACON |


SCON

PSEL

XSEL

XSEL

System configuration





Controllers

PMEC
/AMEC
PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON



Mini
Standard
Controllers
Integrated

Rod
Type

Mini
Standard
Controllers
Integrated

Table/Arm
//Flat Type

Mini
Standard

PMEC JAMEC
PSEP JASEP
ROBO NET JERC2
PCON ACON
SCON
PSEL
ASEL
XSEL

I/O Specifications


■ Input section External input specifications


| | Item | Specifications |
|-----|------------------|---|
| | Input voltage | DC24V ±10% |
| | Input current | 7mA / circuit |
| | ON/OFF voltage | ON voltage (min.) NPN: DC16V / PNP: DC8V |
| OIN | ON/OFF voilage | OFF voltage (max.) NPN: DC5V / PNP: DC19V |
| | Isolation method | Photocoupler |


| NPN Specifications |
|--|
| External power supply +24V Input terminal Inputs R=3.3kΩ |

■ Output section External output specifications

| Item | Specifications |
|-------------------------|---|
| Load Voltage | DC24V |
| Max. load current | 100mA / 1 point 400mA / 8 points in total |
| Residual voltage (Max.) | Max 0.1mA / 1 point |
| Isolation method | Photocoupler |







Explanation of I/O Signal Functions

Two modes can be selected for the ASEL controller: "Program Mode," in which the actuator is operated by entering a program, and "Positioner Mode," in which PLC signals are received and the actuator is moved to designated positions.

The Positioner Mode has the five input patterns listed below to enable various applications.

■ Control Function by Type

| Operation | on mode | Features |
|-----------------|----------------------------|--|
| Progra | n mode | Various operations including linear/arc interpolation operation, path operation ideal for coating processes, etc., archmotion operation and palletizing operation can be performed using the Super SEL language that lets you program complex control actions using simple commands. |
| | Standard mode | This is the basic mode from which operations can be conducted by designating position numbers and inputting the start signal. Push-motion operation and teaching operation are also possible. |
| | Product Change mode | Multiple parts of the same shape with slightly different hole positions can be handled using movement commands to the same position numbers by simply changing the product type number. |
| Positioner mode | 2-axis independent mode | With a 2-axis controller, each axis can be commanded and operated separately. |
| | Teaching mode | In this mode, the slider (rod) moves based on an external signal, when the actuator is stopped, the current location can be registered as position data. |
| | DS-S-C1 Compatible mode | If you were using a DS-S-C1 controller, you can replace it with a ASEL controller without having to change the host programs. *This mode does not ensure actuator compatibility. |



Explanation of I/O Signal Functions

Program mode

| Pin Number | Category | Port No. | Program Mode | Functions | Wiring Diagram |
|------------|------------|----------|------------------------|--|---|
| 1A | P24 | | 24V input | Connect 24V. | |
| 1B | | 016 | Select Program No. 1 | | • |
| 2A | 1 1 | 017 | Select Program No. 2 | | |
| 2B | 1 1 | 018 | Select Program No. 4 | | • |
| 3A | 1 1 | 019 | Select Program No. 8 | Selects the program number to start. | |
| 3B | 1 1 | 020 | Select Program No. 10 | (Input as BCD values to ports 016 to 022) | ••• |
| 4A | 1 1 | 021 | Select Program No. 20 | | ••• |
| 4B | 1 1 | 022 | Select Program No. 40 | | • |
| 5A | 1 1 | 023 | CPU reset | Resets the system to the same state as when the power is turned on. | ••• |
| 5B | 1 | 000 | Start | Starts the program selected by ports 016 to 022. | ••• |
| 6A | 1 1 | 001 | General-purpose input | | ••• |
| 6B | 1 1 | 002 | General-purpose input | | ••• |
| 7A | l l | 003 | General-purpose input | | ••• |
| 7B | Input | 004 | General-purpose input | | ••• |
| 8A | | 005 | General-purpose input | | ••• |
| 8B | 1 | 006 | General-purpose input | | ••• |
| 9A | 1 1 | 007 | General-purpose input | Waits for external input via program instructions. | • • |
| 9B | 1 1 | 008 | General-purpose input | | ••• |
| 10A | 1 1 | 009 | General-purpose input | | ••• |
| 10B | 1 | 010 | General-purpose input | | ••• |
| 11A |] [| 011 | General-purpose input | | ••• |
| 11B | 1 | 012 | General-purpose input | | • |
| 12A | 1 1 | 013 | General-purpose input | | ••• |
| 12B | 1 | 014 | General-purpose input | | ••• |
| 13A | 1 1 | 015 | General-purpose input | | • • |
| 13B | | 300 | Alarm | Turns off when an alarm occurs. (Contact B) | • • •••••••••••••••••••••••••••••••••• |
| 14A |] | 301 | Ready | Turns on when the controller starts up normally and is in an operable state | |
| 14B | | 302 | General-purpose output | | •0• |
| 15A |] <u>.</u> | 303 | General-purpose output | | |
| 15B | Output | 304 | General-purpose output | There are the transport ON/OFF are desired this are the first of the state of the s | - D |
| 16A |] | 305 | General-purpose output | These outputs can be turned ON/OFF as desired via program instructions. | • • • |
| 16B |] | 306 | General-purpose output | | |
| 17A | | 307 | General-purpose output | | •0• |
| 17B | N | | 0V input | Connect 0V. | • |

Positioner mode

| Number | Category | Port No. | Positioner Standard Mode | Functions | Wiring Diagram |
|--------|----------|----------|--------------------------------|--|----------------------|
| 1A | P24 | | 24V input | Connect 24V. | |
| 1B | | 016 | Position input 10 | | — |
| 2A | Ī | 017 | Position input 11 | Specifies the position numbers to move to, using port number 007 to 019 | |
| 2B | Ī | 018 | Position input 12 | The number can be specified either as BCD or binary. | |
| 3A | Ī | 019 | Position input 13 | | |
| 3B | Ì | 020 | - | _ | |
| 4A | Ī | 021 | - | - | |
| 4B | Ī | 022 | - | - | |
| 5A | Ì | 023 | Error reset | Resets minor errors. (Severe errors require a restart.) | |
| 5B | Ī | 000 | Start | Starts moving to the selected position. | |
| 6A | Ì | 001 | Home Return | Performs Home Return. | |
| 6B | Ī | 002 | Servo ON | Switches between Servo ON and OFF. | |
| 7A | | 003 | Push | Performs a push motion. | |
| 7B | Input | 004 | Pause | Pauses the motion when turned OFF, and resumes motion when turned ON. | |
| 8A | Ī | 005 | Cancel | Stops the motion when turned OFF. The remaining motion is canceled. | |
| 8B | Ī | 006 | Interpolation settings | When this signal turned ON for a 2-axis model, the actuator moves by linear interpolation. | |
| 9A | Ī | 007 | Position input 1 | | |
| 9B | Ī | 008 | Position input 2 | | |
| 10A | [| 009 | Position input 3 | Specifies the position numbers to move to, using ports 007 to 019. | |
| 10B | Ī | 010 | Position input 4 | The number can be specified either as BCD or binary. | |
| 11A | Ī | 011 | Position input 5 | The number can be specified either as BCD or binary. | |
| 11B | Ī | 012 | Position input 6 | | |
| 12A | | 013 | Position input 7 | | |
| 12B | [| 014 | Position input 8 | | |
| 13A | | 015 | Position input 9 | | ~ |
| 13B | | 300 | Alarm | Turns off when an alarm occurs. (Contact B) | - ₹0 - |
| 14A | [| 301 | Ready | Turns on when the controller starts up normally and is in an operable state. | - 55 - |
| 14B | [| 302 | Positioning complete | Turns on when the movement to the destination is complete. | |
| 15A | Output [| 303 | Home Return complete | Turns on when the home return operation is complete. | |
| 15B | Output | 304 | Servo ON output | Turns on when servo is ON. | → ♥ |
| 16A | [| 305 | Pushing complete | Turns on when a push motion is complete. | |
| 16B | [| 306 | System battery error | Turns on when the system battery runs low (warning level). | →5 5• |
| 17A | | 307 | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level). | |
| 17B | N | | 0V input | Connect 0V. | |

ASEL **570**



PMEC /AMEC PSEP /ASEP ROBO NET ERC2 PCON ACON SCON PSEL ASEL

ASEL Controller

Slider Type

Mini
Standard
Controllers
Integrated

Rodd
Type
Mini
Standard
Controllers
Integrated

Table/Arm
//Flat Type
Mini
Standard

Cripper/Rotary Type
Linear Servo
Type

Splash-Proof

Controllers

PMEC
/AMEC
/AMEC
PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

XSEL

Explanation of I/O Signal Functions

Positioner, Product-Type Change Mode

| Pin Number | Category | Port No. | Positioner Product Type Change Mode | Functions | Wiring Diagram | | | | |
|------------|----------|----------|--|--|----------------|-----|-------------------------------|--|-----|
| 1A | P24 | | 24V input | Connect 24V. | | | | | |
| 1B | | 016 | Position/Product Type Input 10 | | • | | | | |
| 2A | 1 | 017 | Position/Product Type Input 11 | | ••• | | | | |
| 2B | 1 | 018 | Position/Product Type Input 12 | Specifies the position numbers to move to, and the product type numbers, using ports 007 to 022. | ••• | | | | |
| 3A | | 019 | Position/Product Type Input 13 | | ••• | | | | |
| 3B | 1 | 020 | Position/Product Type Input 14 | The position and product type numbers are assigned by parameter settings. | ••• | | | | |
| 4A | 1 | 021 | Position/Product Type Input 15 | The number can be specified either as BCD or binary. | • • | | | | |
| 4B | 1 | 022 | Position/Product Type Input 16 | | ••• | | | | |
| 5A | 1 | 023 | Error reset | Resets minor errors. (Severe errors require a restart.) | ••• | | | | |
| 5B | 1 | 000 | Start | Starts moving to the selected position. | • | | | | |
| 6A | | 001 | Home Return | Performs Home Return. | ••• | | | | |
| 6B | 1 | 002 | Servo ON | Switches between Servo ON and OFF. | ••• | | | | |
| 7A | | 003 | Push | Performs a push motion. | ••• | | | | |
| 7B | Input | 004 | Pause | Pauses the motion when turned OFF, and resumes motion when turned ON. | ••• | | | | |
| 8A | | 005 | Cancel | Stops the motion when turned OFF. The remaining motion is canceled. | ••• | | | | |
| 8B | | 006 | Interpolation settings | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. | ••• | | | | |
| 9A | | 007 | Position/Product Type Input 1 | | ••• | | | | |
| 9B | | 008 | Position/Product Type Input 2 | Specifies the position numbers to move to, and the product type numbers, | ••• | | | | |
| 10A | 1 | 009 | Position/Product Type Input 3 | | ••• | | | | |
| 10B | | 010 | Position/Product Type Input 4 | | | | | | |
| 11A | | 011 | Position/Product Type Input 5 | using ports 007 to 022. | ••• | | | | |
| 11B | | 012 | Position/Product Type Input 6 | The position and product type numbers are assigned by parameter settings. | | | | | |
| 12A | | | Position/Product Type Input 7 | The number can be specified either as BCD or binary. | ••• | | | | |
| 12B | l | | | ļ | | 014 | Position/Product Type Input 8 | | ••• |
| 13A | | 015 | Position/Product Type Input 9 | | ••• | | | | |
| 13B | | 300 | Alarm | Turns off when an alarm occurs (Contact B) | | | | | |
| 14A | | 301 | Ready | Turns on when the controller starts up normally and is in an operable state. | | | | | |
| 14B | | 302 | Positioning complete | Turns on when the movement to the destination is complete. | F0- | | | | |
| 15A | 0.4 | 303 | Home Return complete | Turns on when the home return operation is complete. | | | | | |
| 15B | Output | 304 | Servo ON output | Turns on when servo is ON. | - D | | | | |
| 16A | | 305 | Pushing complete | Turns on when a push motion is complete. | | | | | |
| 16B | | 306 | System battery error | Turns on when the system battery runs low (warning level). | | | | | |
| 17A | | 307 | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level). | | | | | |
| 17B | N | | 0V input | Connect 0V. | — | | | | |

Positioner, 2-axis Independent Mode

| Pin Number | Category | Port No. | Positioner 2-axis Independent Mode | Functions | Wiring Diagram |
|------------|----------|----------|---------------------------------------|---|---------------------|
| 1A | P24 | | 24V input | Connect 24V. | |
| 1B | | 016 | Position input 7 | | |
| 2A | | 017 | Position input 8 | Specifies the position numbers to move to, using ports 010 to 022. | |
| 2B | | 018 | Position input 9 | The position numbers on the 1st and 2nd axes are assigned by | |
| 3A | | 019 | Position input 10 | parameter settings. | |
| 3B | | 020 | Position input 11 | The number can be specified either as BCD or binary. | |
| 4A | | 021 | Position input 12 | | |
| 4B | | 022 | Position input 13 | | |
| 5A | | 023 | Error reset | Resets minor errors. (Severe errors require a restart.) | |
| 5B | | 000 | Start 1 | Starts movement to the selected position number on the 1st axis. | |
| 6A | | 001 | Home Return 1 | Performs home return on the 1st axis. | |
| 6B | | 002 | Servo ON 1 | Switches between servo ON and OFF for the 1st axis. | |
| 7A | Innut | 003 | Pause 1 | Pauses the motion on 1st axis when turned OFF, and resumes motion when turned ON. | |
| 7B | Input | 004 | Cancel 1 | Cancels the movement on the 1st axis. | |
| 8A | | 005 | Start 2 | Starts the movement to the selected position number on the 2nd axis. | |
| 8B | | 006 | Home Return 2 | Performs home return on the 2nd axis. | |
| 9A | | 007 | Servo ON 2 | Switches between servo ON and OFF for the 2nd axis. | |
| 9B | | 800 | Pause 2 | Pauses the motion on 2nd axis when turned OFF, and resumes when turned ON. | |
| 10A | | 009 | Cancel 2 | Cancels the movement on the 2nd axis. | |
| 10B | 1 | 010 | Position input 1 | 0 | |
| 11A | 1 | 011 | Position input 2 | Specifies the position numbers to move to, using ports 010 to 022. | |
| 11B | 1 | 012 | Position input 3 | The position numbers on the 1st and 2nd axes are assigned by | |
| 12A | 1 | 013 | Position input 4 | parameter settings. | |
| 12B | 1 | 014 | Position input 5 | The number can be specified either as BCD or binary. | |
| 13A | 1 | 015 | Position input 6 | | |
| 13B | | 300 | Alarm | Turns off when an alarm occurs (Contact B) | |
| 14A | | 301 | Ready | Turns on when the controller starts up normally and is in an operable state. | |
| 14B | | 302 | Positioning complete 1 | Turns on when the movement to the specified position on the 1st axis is complete. | ₹ |
| 15A | | 303 | Home Return complete 1 | Turns on when home return on the 1st axis is complete. | |
| 15B | Output | 304 | Servo ON output 1 | Turns on when the 1st axis is in a servo ON state. | ₹ |
| 16A | | 305 | Positioning complete 2 | Turns on when the movement to the specified position on the 2nd axis is complete. | |
| 16B | | 306 | Home Return complete 2 | Turns on when home return on the 2nd axis is complete. | 55 - |
| 17A | | 307 | Servo ON output 2 | Turns on when the 2nd axis is in a servo ON state. | |
| 17B | N | | 0V input | Connect 0V. | |



Explanation of I/O Signal Functions

Positioner, Teaching Mode

| in Number | Category | Port No. | Positioner Teaching Mode | Functions | Wiring Diagram |
|-----------|----------|----------|--------------------------------|---|----------------|
| 1A | P24 | | 24V input | Connect 24V. | |
| 1B | | 016 | JOG- on 1st axis | While the signal is on, the 1st axis is moved in the - (negative) direction. | — |
| 2A | | 017 | JOG+ on 2nd axis | While the signal is on, the 2nd axis is moved in the + (positive) direction. | ••• |
| 2B | | 018 | JOG- on 2nd axis | While the signal is on, the 2nd axis is moved in the - (negative) direction. | ••• |
| 3A | | 019 | Specify inching (0.01mm) | | ••• |
| 3B | | 020 | Specify inching (0.1mm) | Specifies how much to move during inching. | ••• |
| 4A | | 021 | Specify inching (0.5mm) | (Total of the values specified for ports 019 to 022) | • |
| 4B | | 022 | Specify inching (1mm) | | ••• |
| 5A | | 023 | Error reset | Resets minor errors. (Severe errors require a restart.) | • • |
| 5B | | 000 | Start | Starts moving to selected position. | |
| 6A | | 001 | Servo ON | Switches between Servo ON and OFF. | |
| 6B | | 002 | Pause | Pauses the motion when turned OFF, and resumes motion when turned ON. | ••• |
| 7A | | 003 | Position input 1 | | • • |
| 7B | Input | 004 | Position input 2 | | ••• |
| 8A | l | 005 | Position input 3 | | • |
| 8B | | 006 | Position input 4 | B. 4. 000 to 040 | ••• |
| 9A | | 007 | Position input 5 | Ports 003 to 013 are used to specify the position number to move, and the | • • |
| 9B | | 008 | Position input 6 | position number for inputting the current position. | ••• |
| 10A | | 009 | Position input 7 | When the teaching mode setting on port 014 is in the ON state, the current | • |
| 10B | | 010 | Position input 8 | | ••• |
| 11A | | 011 | Position input 9 | value is written to the specified position number. | ••• |
| 11B | | 012 | Position input 10 | | ••• |
| 12A | | 013 | Position input 11 | | • |
| 12B | | 014 | Teaching mode setting | | ••• |
| 13A | | 015 | JOG+ on 1st axis | While the signal is input, the 1st axis is moved in the + (positive) direction. | |
| 13B | | 300 | Alarm | Turns off when an alarm occurs. (Contact B) | 1 |
| 14A | | 301 | Ready | Turns on when the controller starts up normally and is in an operable state. | |
| 14B | | 302 | Positioning complete | Turns on when the movement to the destination is complete. | - |
| 15A | | 303 | Home return complete | Turns on when the home return operation is complete. | |
| 15B | Output | 304 | Servo ON output | Turns on when servo is ON. | 1 |
| 16A | | 305 | - | - | |
| 16B | | 306 | System battery error | Turns on when the system battery runs low (warning level). | - 5 |
| 17A | | 307 | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level). | |
| 17B | N | | 0V input | Connect 0V. | |

Positioner, DS-S-C1 Compatible Mode

| in Number | Category | Port No. | Positioner DS-S-C1 Compatible Mode | Functions | Wiring Diagram |
|-----------|----------|----------|---------------------------------------|---|----------------|
| 1A | P24 | | 24V input | Connect 24V. | |
| 1B | | 016 | Position No. 1000 | (Same as ports 004 through 015) | ••• |
| 2A | | 017 | - | | ••• |
| 2B | | 018 | - | = | ••• |
| 3A | | 019 | - | - | ••• |
| 3B | | 020 | - | = | ••• |
| 4A | | 021 | - | = | • • |
| 4B | | 022 | - | = | ••• |
| 5A | | 023 | CPU reset | Resets the system to the same state as when the power is turned on. | |
| 5B | | 000 | Start | Starts moving to selected position. | |
| 6A | [| 001 | Hold (Pause) | Pauses the motion when turned ON, and resumes when turned OFF. | ••• |
| 6B | | 002 | Cancel | Stops the motion when turned ON. The remaining motion is canceled. | |
| 7A | Innut | 003 | Interpolation settings | When this signal is turned ON for a 2-axis model, the actuator moves by linear interpolation. | |
| 7B | Input | 004 | Position No. 1 | | ••• |
| 8A | | 005 | Position No. 2 | | ••• |
| 8B | | 006 | Position No. 4 | | ••• |
| 9A | | 007 | Position No. 8 | | ••• |
| 9B | | 800 | Position No. 10 | Ports 004 through 016 are used to specify the position number to move. | ••• |
| 10A | | 009 | Position No. 20 | The numbers are specified as BCD. | ••• |
| 10B | | 010 | Position No. 40 | The numbers are specified as BCD. | ••• |
| 11A | | 011 | Position No. 80 | | ••• |
| 11B | | 012 | Position No. 100 | | ••• |
| 12A | | 013 | Position No. 200 | | ••• |
| 12B | | 014 | Position No. 400 | | ••• |
| 13A | | 015 | Position No. 800 | | - |
| 13B | | 300 | Alarm | Turns off when an alarm occurs. (Contact A) | |
| 14A | | 301 | Ready | Turns on when the controller starts up normally and is in an operable state. | |
| 14B | | 302 | Positioning complete | Turns on when the movement to the destination is complete. | |
| 15A | Output | 303 | - | - | •5• |
| 15B | Carput | 304 | - | = | |
| 16A | | 305 | - | - | |
| 16B | | 306 | System battery error | Turns on when the system battery runs low (warning level). | |
| 17A | | 307 | Absolute encoder battery error | Turns on when the battery for the absolute encoder runs low (warning level). | •5• |
| 17B | N | | 0V input | Connect 0V. | |

ASEL **572**



Splash-Proof

Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

XSEL

ASEL Controller

Table of specifications

| | Item | Specifications |
|---------------------------|--|---|
| _ | Connected actuator | RCA/RCA2 Series Actuator |
| suc | Input Voltage | DC24V ±10% |
| atic | Power Supply Capacity | Control power supply (Max. 1.2A) + motor power supply (See the table below) |
| iệ l | Dielectric strength voltage | DC500V 10MΩ or higher |
| 96 | Withstand voltage | AC500V 1 min. |
| S | Rush current | Max. 30A |
| Basic Specifications | Vibration resistance | XYZ directions 10 to 57Hz, One side amplitude: 0.035mm (continuous), 0.075mm (intermittent) 58 to 150 Hz 4.9 m/s² (continuous), 9.8 m/s² (intermittent) |
| _ | Number of control axes | 1 axis / 2 axis |
| Control specification | Maximum total output of connected axis | 60W (30W + 30W) |
| cat | Position detection method | Incremental encoder / Absolute encoder |
| Control | Speed setting | 1mm/sec and up, the maximum depends on actuator specifications |
| g | Acceleration setting | 0.01G and up, the maximum depends on the actuator |
| | Operating method | Program operation / Positioner operation (switchable) |
| | Programming language | Super SEL language |
| | Number of programs | 64 programs |
| Program | Number of program steps | 2000 steps |
| g | Number of multi-tasking programs | 8 points |
| F | Positioning Points | 1500 points |
| | Data memory device | FLASHROM (A system-memory backup battery can be added as an option) |
| | Data input method | Teaching pendant or PC software |
| _ | Number of I/O | 24 input points / 8 output points (NPN or PNP selectable) |
| į. | I/O power | Externally supplied 24VDC ± 10% |
| cat | PIO cable | CB-DS-PIO □□□ (supplied with the controller) |
| Communication | Serial communications function | RS232C (D-Sub Half-pitch connector) / USB connector |
| Ę | Field Network | DeviceNet, CC-Link, ProfiBus |
| ō | Motor Cable | CB-ACS-MA □□□ (Max. 20m) |
| | Encoder cable | CB-ACS-PA □ □ □ (Max. 20m) |
| ns | Protection function | Motor overcurrent, Motor driver temperature check, Overload check, Encoder open-circuit check Soft limit over, system error, battery error, etc. |
| 를 를 | Ambient operating humidity and temperature | 0 to 40°C 10 to 95% (non-condensing) |
| General specifications | Ambient atmosphere | Free from corrosive gases. In particular, there shall be no significant dust. |
| 8 8 | Protection class | IP20 |
| & | Weight | Approx. 450g |
| | External dimensions | 43 mm (W) x 159 mm (H) x 110 mm (D) |


| | | | 1-Axis specification | | | | 2-Axis specification | | | |
|---|---------------|--|---|--------------|--------------|--------------|---|--------------|--------------|--------------|
| | Actuator type | | Standard specifications/high acceleration and deceleration model | | Power-saving | | Standard specifications/high acceleration and deceleration model | | Power-saving | |
| Motor power supply capacity (Note1) | | | Rated | Max. (Note2) | Rated | Max. (Note3) | Rated | Max. (Note2) | Rated | Max. (Note3) |
| | RCA RCA2 | 10W, 20W [Model symbol: 20] | 1.3A | 4.4A | 1.3A | 2.5A | 2.6A | 8.8A | 2.6A | 5.0A |
| | | 30W | 1.3A | 4.4A | 1.3A | 2.2A | 2.6A | 8.8A | 2.6A | 4.4A |
| | | 20W [Model symbol: 20S] SA4, RA3, TA5 type dedicated | 1.7A | 5.1A | 1.7A | 3.4A | 3.4A | 10.2A | 3.4A | 6.8A |
| | RCL | 2W | 0.8A | 4.6A | - | - | 1.6A | 9.2A | - | - |
| | | 5W | 1.0A | 6.4A | - | - | 2.0A | 12.8A | - | - |
| | | 10W | 1.3A | 6.4A | - | - | 2.6A | 12.8A | - | - |


(Note 1) For both 1-axis and 2-axis specifications, approx. 30.0A inrush current flows for 5 ms when the control power supply is turned on.

(Note 2) Max. current at accelerating/decelerating

(Note 3) Current reaches the maximum when detecting the servo motor excitation phase at the first servo on after the power is on. (Normal: Approx. 1 to 2 sec., Max.: 10 sec) (Note 4) Other than motor power supply capacity, it increases 0.5A for control power.

External Dimensions






573 ASEL




PMEC / AMEC PSEP / ASEP ROBO NET PCON ACON SCON PSEL ASEL

Name of Each Part



13



1 Motor connector for axis 1

Connect the motor cable of the axis 1 actuator.

2 Motor connector for axis 2

Connect the motor cable of the axis 2 actuator.

3 Brake switch for axis 1

This switch is used to release the axis brake. Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

4 Encoder connector for axis 1

Connect the encoder cable of the axis 1 actuator.

5 Brake switch for axis 2

This switch is used to release the axis brake.

Setting it to the left position (RLS side) forcibly releases the brake, while setting it to the right position (NOM side) causes the controller to automatically control the brake.

6 Encoder connector for axis 2

Connect the encoder cable of the axis 2 actuator.

7 Status indicator LEDs

These LEDs are used to indicate the operating condition of the controller.

The LED status indicators are as follows:

PWR : Power is input to controller.

RDY : The controller is ready to perform program

operation.

The controller is abnormal.

EMG An emergency stop is actuated and the drive

source is cut off. The axis 1 actuator servo is on.

SV2 : The axis 2 actuator servo is on.

8 Panel unit connector

A connector for the panel unit (optional) that displays the controller status and error codes.

9 I/O Connector

A connector for interface I/Os.

34-pin flat cable connector for DIO (24IN/8OUT) interface

I/O power is also supplied to the controller via this connector (Pin No. 1 and No. 34).

This switch is used to specify the running mode of the controller. The left position indicates the MANU (manual operation) mode, while the right position indicates the AUTO (automatic operation) mode. Teaching can only be performed in manual operation, and automatic operation using external I/Os is not possible in the MANU mode.

11 USB connector

A connector for PC connection via USB. If the USB connector is connected, the TP connector is disabled and all communication inputs to the TP connector are cut off.

12 Teaching pendant connector

A half-pitch I/O 26-pin connector that connects a teaching pendant when the running mode is MANU. A special conversion cable is needed to connect a conventional Dsub, 25-pin connector.

13 System-memory backup battery connector

If you wish to retain the various data recorded in the SRAM of the controller even after the power is cut off, connect the necessary battery to this connector. This battery is installed externally to the unit. The controller does not come standard with the battery (Option).

14 Motor power input connector

This connector is used to input the motor power. It consists of a 2-pin, 2-piece connector by Phoenix Contact.

15 External regenerative resistor connector

A connector for the regenerative resistor that must be connected when the built-in regenerative resistor alone does not offer sufficient capacity in high-acceleration/ high-load operation, etc.

Whether or not an external regenerative resistor is necessary depends on the conditions of your specific application such as the axis configuration.

16 Control power/System input connector

This connector is used to connect the control power input, emergency stop switch, and enable switch. It consists of a Phoenix Contact 6-pin 2-piece connector.

17 Absolute-data backup battery connector for axis 1

A connector for the battery that backs up absolute data when the actuator uses an absolute encoder. Secure installation of the battery is the customer's responsibility.

18 Absolute-data backup battery connector for axis 2

A connector for the battery that backs up absolute data when the actuator uses an absolute encoder. Secure installation of the battery is the customer's responsibility.

10 Mode switch



Controllers

PMEC
/AMEC

PSEP
/ASEP

ROBO
NET

ERC2

PCON

ACON

SCON

PSEL

ASEL

YSEL



ASEL Controller

Option

■ Teaching Pendant


Features This is a teaching device that provides information on functions such as position input, test runs, and monitoring.

Model

Mini
Standard
Controllers
Integrated
Rod
Type
Mini
Standard
Controllers
Integrated
Table/Arm
//Flat Type
Mini
Standard
Gripper
Rodary Typ

PMEC /AMEC PSEP /ASEP ROBO NET ERC2 PCON ACON SCON PSEL SSEL


| Model | Description | | | |
|----------|--|--|--|--|
| SEL-T-J | Standard type with adapter cable | | | |
| SEL-TD-J | Equipped with a deadman switch and adapter cable | | | |



SEL-T dedicated options

Model HK-1 Model STR-1





Specifications

| Item | SEL-T-J | SEL-TD-J | | | |
|-------------------------------------|-----------------------------------|-----------|--|--|--|
| 3-position Enable Switch | No | Yes | | | |
| ANSI/UL standards | Non-compliant | Compliant | | | |
| CE mark | Compliant | | | | |
| Display | 20 char. × 4 lines | | | | |
| Ambient Operating Temp./Humidity | 0~40°C 10~90% RH (non-condensing) | | | | |
| Protective structure | IP54 | | | | |
| Weight | Approx. 0.4kg (not incl. cable) | | | | |


■PC Software (Windows Only)

Features A startup support software for entering programs/positions, performing test runs, and monitoring. More functions have been added for debugging, and improvements have been made to shorten the start-up time.

IA-101-X-MW-J (with RS232C cable + adapter cable) Model

Configuration

Model





IA-101-X-USB (with USB cable) Note: Only versions 7.0.0.0 and later can

Absolute Data Backup Battery


memory backup. AB-5

■ Features

Model







System Memory Backup Battery

be used with the PSEL controller.


This battery is required when you are using global flags in the program and you want to retain your data even after the power has been turned OFF. ■ Features

AB-5-CS (with case) Model AB-5 (Standalone battery)



Panel Unit Display device that shows the error code from the controller or the Features

currently running program number. Model PU-1 (Cable length: 3m)





Battery for saving absolute data, when operating an actuator with an absolute encoder.

Same as the battery used for system

Option

Dummy Plug

■ Features

When connecting the ASEL controller to a computer with a USB cable, this plug is inserted in the teaching port to shut off the enable circuit.

(Supplied with the PC software IA-101-X-USB)

DP-3 Model



」∟□ / CB-ACS-PA □□□ -RB

USB Cable

Features A cable for connecting the controller to the USB port to a computer.
A controller with no USB port (e.g. XSEL) can be connected to the USB

RS232C cabbe to the USB cable via a USB adapter. (See PC software IA-101-X-USBMW)

CB-SEL-USB030 (Cable length: 3m) Model



Adapter Cable

*The standard cable for the encoder cable is a normal cable. *Enter the cable length (L) into . Compatible to a maximum of 20 meters. A robot cable can be specified as an option. Ex.: 080 = 8 m

Features An adapter cable to connect the D-sub 25-pin connector from the teaching pendant or a PC to the teaching connector (half-pitch) of the ASEL controller.

CB-SEL-SJ002 (Cable length: 0.2m) Model



PSEP /ASEP ROBO NET ERC2
PCON ACON SCON PSEL ASEL

Spare Parts

Model CB-ACS-PA

When you need spare parts after purchasing the product, such as when replacing a cable, refer to the list of models below.

